

ENERGY AUDIT REPORT

FY 2025–26



IIHMR UNIVERSITY
JAIPUR, RAJASTHAN

Submitted by:



Enviraj Consulting Private Limited

(An ISO 14001:2015 Certified Company)

F-29 Bhagat Singh Nagar,

Airport Road, Gwalior

Madhya Pradesh - 474005

www.enviraj.com

April, 2026

Approval and Sign-off

Prepared By

For IIHMR University



Rajdeep Pandey

Environmental Consultant

Certified Environmental and Energy Auditor
(ISO 14001:2015, ISO 50001:2018)



Nitin Bhushan

Chief Administrative Officer



Manish Singh Sisodiya

Assistant Registrar



Shantam Jain

Assistant Manager - IQAC



OM Joshi

Executive – Administration

This report has been prepared based on the information provided by the institute, available records, and observations made during the site visit.

Contents

EXECUTIVE SUMMARY	4
1. Introduction.....	5
2. Institute Profile.....	5
2.1 About Institute.....	5
2.2 Site Location	5
3. Objective and Scope.....	6
4. Methodology	6
5. Energy Consumption Analysis	7
5.1 Energy Sources	7
5.2 Electricity Infrastructure Details.....	7
5.3 Electrical Load Assessment.....	7
5.4 Load Distribution Analysis	9
5.5 Energy Conservation Measures Implemented	9
5.6 Electricity Consumption Analysis.....	10
5.7 Energy Consumption from Other Sources.....	11
5.8 Annual Energy Use Summary	12
5.9 Energy Intensity	13
6 Electricity Cost Analysis	13
6.1 Average electricity cost from Grid.....	13
6.2 Power Factor Analysis.....	13
6.3 DG Sets Energy cost	14
6.4 Solar Cost Savings	14
7. Conclusion and Recommendations	15

EXECUTIVE SUMMARY

This energy audit assesses energy consumption at IIHMR University, Jaipur, focusing on key load drivers, system performance, and improvement opportunities.

Electricity is the primary energy source, with air conditioning identified as the dominant load. Consumption increases during summer and monsoon months due to cooling demand. Water pumping and utility systems form the next major load category due to dependence on groundwater extraction and wastewater treatment, while lighting and IT loads remain distributed across campus operations.

The electrical system operates efficiently, with the power factor consistently above 0.95 and an annual average of 0.98. DG sets are used strictly for backup. LPG used for cooking contributes a significant share of total energy use.

Priority areas include strengthening energy monitoring, improving load management, and expanding renewable energy capacity in a phased manner to enhance efficiency and reduce operating costs.

Key Performance Indicators

Parameter	Value	Unit
Total Energy Consumption	11,44,477	kWh (Equivalent)
Electricity Consumption	10,04,907	kWh
Average Power Factor	0.98	—
Renewable Electricity Share	13.33	%
Renewable Energy Share	11.71	%
Electricity Use Intensity	1,168	kWh/student/year
Energy Use Intensity	1,331	kWh/student/year

Cost Performance Indicators

Parameter	Value
Average Electricity Cost	₹12.81/kWh
Solar Savings	₹17.71 lakh/year
DG Cost of Generation	₹26/kWh
Power Factor Incentive	₹1.49 lakh/year

1. Introduction

The energy demand in India continues to grow steadily, with electricity generation still predominantly dependent on conventional sources. This underscores the direct relationship between energy consumption and associated environmental impacts.

The IIHMR University, Jaipur, has undertaken initiatives to integrate renewable energy within its campus operations and improve its energy performance.

The present energy audit has been conducted to assess energy consumption patterns, evaluate system performance, and identify opportunities for improving energy efficiency. The audit provides a structured basis for reducing energy costs, optimizing resource use, and supporting long-term sustainability planning.

2. Institute Profile

2.1 About Institute

IIHMR University, Jaipur, was established in 2014 under the IIHMR University Act, 2014 by the Government of Rajasthan. It has its origin in the Indian Institute of Health Management Research, founded in 1984, and functions as a postgraduate research university in the field of health and development studies.


The campus is spread over approximately 14.37 acres and comprises academic, administrative, and residential facilities.

The University operates through five schools covering health management, public health, pharmaceutical management, development studies, and digital health. It offers MBA programs in Hospital and Health Management, Pharmaceutical Management, Healthcare Analytics, and Development Management, along with a Master of Public Health program. Doctoral programs are offered in public health, health management, hospital management, digital health, and development management, along with executive programs in related domains.

The University maintains academic collaborations with national and international institutions for academic exchange and research. It has a diverse student base from different regions and academic backgrounds, supporting an interdisciplinary learning environment.

2.2 Site Location

IIHMR University is located in Jaipur, Rajasthan, within a semi-arid climatic zone characterized by high temperatures, low to moderate rainfall, and water stress conditions. The climatic conditions significantly influence energy consumption patterns, particularly due to high cooling demand during summer months.



3. Objective and Scope

a) Objective

The objective of the energy audit is to assess energy consumption patterns of the institute, establish baseline energy performance, and identify opportunities for improving energy efficiency and reducing energy costs. The audit also aims to evaluate key energy performance indicators and recommend practical measures for performance improvement.

b) Scope

The scope of the audit covers analysis of electricity consumption and energy use within the campus, including major systems such as lighting, air conditioning, water pumping, and other significant electrical loads. The assessment is based on available utility data, equipment details, and operational practices, with focus on identifying energy saving opportunities and improving energy performance.

4. Methodology

The methodology adopted for the audit comprises the following steps:

i. Data Collection

Data was collected through site visits, observations, interaction with concerned personnel, and review of available records including electricity bills, equipment inventory, and operational data.

ii. Data Analysis

The collected data was analysed to assess energy consumption patterns, identify major energy consuming systems, and evaluate energy performance indicators such as energy intensity.

iii. Findings and Recommendations

Based on analysis and observations, practical and feasible recommendations were developed to improve energy efficiency and optimize energy use.

5. Energy Consumption Analysis

5.1 Energy Sources

The campus primarily relies on grid electricity supplied by the Jaipur Vidyut Vitran Nigam to meet its energy requirements across academic, administrative, and residential facilities.

Backup power is provided through diesel generator sets to ensure continuity of operations during grid outages. The institute has also adopted renewable energy through rooftop solar photovoltaic systems, which contribute to a portion of the campus electricity demand and reduce dependence on conventional energy sources.

In addition, diesel and LPG are used for transportation and cooking purposes respectively.

5.2 Electricity Infrastructure Details

Source / System	Capacity / Rating	Quantity	Purpose	Remarks
Grid Electricity	1,250 kVA (Transformer)	1	Primary power supply	Main source of energy
DG Set	320 kVA, 250 kVA	2	Backup power supply	Used during power outages
Solar PV	100 kWp	1	Renewable generation	Grid connected rooftop system
Capacitor Bank & APFC	350 kVAR (Combined)	Installed system	Power factor correction	Improves electrical efficiency and reduces losses

5.3 Electrical Load Assessment

The electrical load characteristics of the campus were reviewed to understand demand levels, load distribution, and system utilization.

The sanctioned load of the institute is 950 kW, with a reported connected load of 950 kW. The contract demand is maintained at 900 kVA for billing purposes. Based on available records, the connected load is within the sanctioned limit.

However, a complete and updated equipment inventory was not available. Accordingly, the load assessment has been carried out using available data, supported by site observations and reference information from previous records.

The connected load summary is presented below:

Equipment	Watt (W)	Number
Major Loads		
Air Conditioning (Split / Window / Tower Units)	Typical 1,500–3,500 per unit	500
Air Conditioning (VRV Systems)	Approx. 30,000–32,000 per system (26 TR basis)	2
Mechanical Loads (Water & Utilities)		
Submersible Pump (Borewell)	5,593 (7.5 HP)	1
Submersible Pump (Borewell)	2,610 (3.5 HP)	2
Open Well Pump	5,593 (7.5 HP)	1
Open Well Pump	3,729 (5 HP)	1
STP Pump	2,237 (3 HP)	6
STP Pump	746 (1 HP)	1
Submersible STP Pump	2,237 (3 HP)	1
RO System	120	16
Water Cooler	600	16
Heating Loads		
Room Heater / Blower	1,000	100
Microwave Oven	1,000	34
IT & Office Loads		
Desktop	200	312
Printers & Scanners	Typical 300–600	97
Other IT Equipment (Servers, WiFi access points, UPS, projectors, network switches, digital displays)	Typical 100–800	244
CCTV Camera	10	158
Lighting Loads		
LED High Mast	20	5
LED Lamp	3	198
LED Lights / Bulbs	Typical 5–35	2,872
LED Panel	Typical 50–100	66
CFL	Typical 25–55	25
Tube Light	Typical 36–40	838
Focus Light	100	40
Foot Light	20	20
Ventilation & Fans		

Ceiling Fan	56	700
Exhaust Fan (18")	450	40
Exhaust Fan (6")	150	250
Miscellaneous		
Hand Dryer	500	20
Refrigerator (65 L)	100	44

5.4 Load Distribution Analysis

The connected load has been categorized into major functional groups to understand the distribution of energy demand across different systems.

Air conditioning systems constitute the dominant share of the connected load, indicating cooling as the primary energy driver within the campus. Water pumping and utility systems form the next significant load category due to dependence on groundwater extraction and treatment systems.

Lighting and IT equipment represent distributed loads across academic and administrative areas; while heating and miscellaneous appliances contribute comparatively lower shares.

5.5 Energy Conservation Measures Implemented

The institute has implemented several energy conservation measures aimed at improving energy efficiency and reducing operational energy consumption. These measures contribute to optimized system performance and cost savings.

a) Motion Sensors

Motion sensors have been installed in selected areas such as corridors, washrooms, and low-occupancy spaces. These sensors automatically control lighting based on occupancy, thereby reducing unnecessary energy consumption during non-utilized periods.

b) Capacitor Bank and APFC System

The institute has installed capacitor banks along with an Automatic Power Factor Correction (APFC) system to maintain a high-power factor. This reduces reactive power losses, improves electrical system efficiency, and results in financial benefits through power factor incentives.

S. No	Particular	Capacity	No.
1	Capacitor Bank	100 kVAR	2
2	Capacitor Bank	25 kVAR	1
3	APFC	100 kVAR	1
4	APFC	25 kVAR	1

5.6 Electricity Consumption Analysis

The total annual electricity consumption of the campus is 10,04,907 kWh. Monthly consumption trends indicate higher electricity demand during peak cooling periods (August–September), with reduced consumption during winter months.

Solar energy contribution remains relatively stable across months, while DG usage is minimal and limited to backup requirements.

Electricity Consumption Accounting

Total electricity consumption is calculated as the sum of:

- Grid electricity (net import basis)
- Solar energy self-consumed
- DG generation


The solar PV system is predominantly utilized for on-site consumption, with minimal export to the grid. Under the net metering mechanism, solar generation directly offsets internal demand, thereby reducing net grid import.

Accordingly, net grid import represents residual electricity demand after on-site renewable contribution, while total electricity consumption reflects actual campus electricity use.


Month	Grid Electricity (Net Import Basis) (kWh)	Solar Energy - Self Use (kWh)	DG Generation (kWh)	Total Electricity Consumption (kWh)
April	78,710	15,464	875	95,049
May	87,064	14,563	875	1,02,502
June	68,132	11,616	—	79,748
July	70,340	9,160	—	79,500
August	1,22,190	6,075	—	1,28,265
September	1,17,545	4,768	2,625	1,24,938
October	60,460	11,347	875	72,682
November	51,400	11,420	—	62,820
December	47,280	11,844	—	59,124
January	58,465	10,936	875	70,276
February	45,405	12,463	875	58,743
March	56,920	14,340	—	71,260
Total	8,63,911	1,33,996	7,000	10,04,907

DG generation is estimated using 1 litre diesel = 3.5 kWh (electrical output), based on standard DG efficiency assumptions due to unavailability of generation records.

Monthly Electricity Consumption by Energy Source (kWh)



Electricity Source Distribution (%)



5.7 Energy Consumption from Other Sources

In addition to electricity, LPG is used for cooking, while diesel is used for transportation.

LPG Gas Consumption

Area	Annual Consumption (kg)	kWh Equivalent*
Mess/Canteen	8,208	1,05,062
Pantry	342	4,378
Total	8,550	1,09,440

*LPG energy content is considered as 12.8 kWh/kg on NCV Basis

Transportation - Diesel

Vehicle	Quantity (L)	kWh Equivalent*
Innova	2,213	22,130
Tempo Traveller	800	8,000
Total	3,013	30,130


*Diesel energy content is considered as 10 kWh/L on NCV Basis

5.8 Annual Energy Use Summary

The campus energy mix is dominated by grid electricity (75.49%), followed by solar energy (11.71%) and LPG usage (9.56%). DG generation and transportation diesel contribute relatively small shares.

Energy Source	kWh Equivalent	% Share
Grid Electricity (Net Import)	8,63,911	75.49
Solar Energy – Self Use	1,33,996	11.71
DG Generation	7,000	0.61
LPG - Cooking	1,09,440	9.56
Diesel - Transportation	30,130	2.63
Total Consumption	11,44,477	100.00

Energy Source Distribution (Campus Energy Mix)



5.9 Energy Intensity

The electricity use intensity is 1,168 kWh per student per year, while the total energy consumption intensity is 1,331 kWh per student per year. These indicators provide a baseline for benchmarking future energy performance and monitoring efficiency improvements.

Particular	Value
No. of Students (Nos)	860
Electricity Use Intensity (kWh/student)	1,168
Energy Use Intensity (kWh/student)	1,331

6 Electricity Cost Analysis

6.1 Average electricity cost from Grid

The average electricity cost from grid supply is ₹12.81 per kWh. A higher cost per unit is observed during winter months due to lower consumption and higher impact of fixed charges. Conversely, lower per-unit cost during peak consumption months indicates better utilization of demand charges. This reflects the influence of tariff structure on electricity cost.

Month	Net import	Total Bill	Average Electricity Cost (₹/kWh)
April	78,710	9,74,861	12.39
May	87,064	10,51,971	12.08
June	68,132	8,40,976	12.34
July	70,340	8,86,678	12.61
August	1,22,190	13,83,932	11.33
September	1,17,545	13,65,435	11.62
October	60,460	8,44,279	13.96
November	51,400	7,47,373	14.54
December	47,280	7,10,687	15.03
January	58,465	8,16,233	13.96
February	45,405	6,90,247	15.20
March	56,920	7,50,000	13.18
Total	8,63,911	1,10,62,672	12.81

6.2 Power Factor Analysis

The power factor is consistently maintained above 0.95 across all months, with an annual average of 0.98, indicating efficient electrical system operation and effective reactive power management.

The institute has benefited from power factor incentives amounting to approximately ₹1.49 lakh annually. This indicates that the installed capacitor banks and APFC system are functioning effectively.

Month	Power Factor (P.F)	P.F incentive
April	0.977	11,864
May	0.977	13,063
June	0.982	13,183
July	0.983	14,258
August	0.991	33,384
September	0.991	32,160
October	0.973	6,681
November	0.976	6,990
December	0.967	3,416
January	0.98	9,939
February	0.971	4,245
March	—	—
Total		1,49,183

Data for the month of March was not available.

6.3 DG Sets Energy cost

The DG sets are primarily used as backup during power outages, with total annual generation of 7,000 kWh. The cost of electricity generated from DG sets is approximately ₹26 per kWh, which is significantly higher than grid electricity. This highlights that DG operation is economically unfavourable and should remain limited to emergency usage.

Annual Diesel consumption (L)	kWh Generated	Average Diesel Cost (₹)	Cost per Unit (₹)
2,000	7,000	91	26

6.4 Solar Cost Savings

The solar PV system generated 1,34,320 kWh annually, contributing to direct reduction in grid electricity consumption. The estimated annual cost savings from solar energy is ₹17.71 lakh.

The system demonstrates consistent performance across the year, with slightly reduced output during monsoon months.

Month	Total Solar Generation*	Net Savings
April	15,464	2,03,970
May	14,564	1,92,099
June	11,704	1,54,376
July	9,160	1,20,820
August	6,080	80,195
September	4,768	62,890
October	11,572	1,52,635
November	11,420	1,50,630
December	11,844	1,56,222
January	10,936	1,44,246
February	12,468	1,64,453

March	14,340	1,89,145
Total	1,34,320	17,71,681

* Total solar generation includes both self-consumption and grid export.

7. Conclusion and Recommendations

The campus energy profile is driven by electricity consumption, with air conditioning systems as the primary load. LPG contributes a significant share of total energy use, while solar energy provides partial support through on-site generation. Energy consumption varies seasonally, with higher demand during periods of increased cooling requirement. Water pumping systems also contribute notably due to groundwater dependence.

The electrical system is operating efficiently, supported by high power factor levels and effective functioning of capacitor banks and APFC systems. DG sets are used strictly for backup. The campus has a stable energy infrastructure with partial integration of renewable energy. Improvement opportunities lie in structured energy monitoring, optimized operational practices, and phased expansion of solar capacity.

These actions will improve energy efficiency, reduce operating costs, and support long-term sustainability performance.

Recommendations

Area	Recommendation	Action Plan	Impact	Priority
Energy Monitoring & Data	Establish structured equipment inventory	Maintain an updated electrical load inventory including wattage, quantity, and location.	Foundation for all future audits and decisions	High
	Implement sub-metering (building-wise)	Install submeters for academic blocks, hostels, utilities (STP, pumps)	Enables building-wise energy intensity tracking	High
	Monthly energy tracking system	Record electricity, DG fuel, LPG consumption, solar generation, and vehicle diesel on monthly basis	Improves control and anomaly detection	High
	Track asset lifecycle	Maintain yearly record of new equipment additions and discarded units	Ensures accurate load and planning data	High
	Introduce Electricity Use Intensity (kWh/m ² /year)	Assess total built-up area of buildings and track electricity use intensity (kWh/m ² /year) alongside existing per student metrics	Enables benchmarking and tracking	Medium

Load Management (TOD Optimization)	Shift non-critical loads to off-peak hours	Schedule groundwater pumping, STP operations, and water treatment during non-peak hours (Day-time)	Reduces TOD charges	High
	Optimize operational scheduling	Avoid simultaneous operation of high-load systems where not required	Reduces peak demand impact	Medium
Air Conditioning	Phased replacement of inefficient ACs	Replace older units in phases (e.g., 5–10% annually) with 4/5 star or inverter ACs, prioritizing high-usage areas	Significant long-term savings	High
	Improve operational control	Maintain temperature settings (24–26°C), restrict use in unoccupied areas	Immediate energy savings	High
Lighting & Fans	Upgrade to efficient systems	Replace conventional fans with BLDC fans and remaining tube lights/CFLs with LED	High savings with short payback	High
Renewable Energy	Expand solar PV capacity	Assess rooftop solar potential during the current year and plan phased installation in subsequent period based on feasibility.	Reduces grid dependency and cost	High
Cooking Energy	Evaluate transition to PNG	Assess feasibility of switching from LPG to PNG based on availability	Lower cost and reduced emissions	Medium
DG Set Operation	Restrict DG usage	Operate DG sets strictly during grid outages and critical operations; avoid non-essential usage, particularly in residential areas during daytime.	Reduced emissions and cost savings	Medium